U. S. Department of Homeland Security
United States Coast Guard
Certificate of Approval

Coast Guard Approval Number: 162.029/257/0 Expires: 23 October 2027

FIXED FIRE EXTINGUISHING SYSTEM

Fireaway Inc
5852 Baker Road
Minnetonka MN 55345

Stat-X Models: 30T, 60MT, 100T, 250T, 250MT, 500T, 1000MT aerosol generators; with associated brass mechanical and thermal actuators (158F - 254F), and control unit as a pre-engineered fire extinguishing system.

Fire suppression system is designed to protect against Class A, B and C fires, in both normally unoccupied and normally occupied spaces. Maximum protected gross volume for an unoccupied space is 321 cu. ft (9.1 cu. m) and a maximum height of 8ft (2.5m) for a single thermal unit; or a maximum volume of 2568cu. ft (73 cu. m) with a maximum height of 16 ft (4.9m) for a series of mechanical units in either normally occupied or unoccupied spaces; see approved manual for details. M model generators are mechanical-manual, T model are thermal-automatic.

Systems intended for use in normally occupied spaces or spaces larger than 1000cu. ft must have a pre-discharge alarm. Installations are subject to OCMI review. Systems may be installed with additional manufacturer supplied accessories including Advantage Control Panel. Stat-X system is deemed equivalent to a gas-based fire suppression system within its dimensional limitations.

Identifying Data: Underwriters Laboratory (UL) Certification of Compliance EX15004 dated September 02 2021. Fireaway manual PN 19402 ver 1.0 and USCG Letter dated October 23, 2022

Follow-up Program: UL

*** End ***

THIS IS TO CERTIFY THAT the above named manufacturer has submitted to the undersigned satisfactory evidence that the item specified herein complies with the applicable laws and regulations as outlined on the reverse side of this Certificate, and approval is hereby given. This approval shall be in effect until the expiration date hereon unless sooner canceled or suspended by proper authority.

GIVEN UNDER MY HAND THIS 23rd DAY OF OCTOBER 2022, AT WASHINGTON D.C.

B. A. BALDWIN
Chief, Lifesaving and Fire Safety Division
BY DIRECTION OF THE COMMANDANT

TERMS: The approval of the item described on the face of the Certificate has been based upon the submittal of satisfactory evidence that the item complies with the applicable provisions of the navigation and shipping laws and the applicable regulations in Title 33 and/or Title 46 of the Code of Federal Regulations. The approval is subject to any conditions noted on this Certificate and in the applicable laws and regulations governing the use of the item on vessels subject to Coast Guard inspection or on other vessels and boats.

Consideration will be given to an extension of this approval provided application is made 3 months prior to the expiration date of this Certificate.

The approval holder is responsible for making sure that the required inspections or tests of materials or devices covered by this approval are carried out during production as prescribed in the applicable regulations.

The approval of the item covered by this certificate is valid only so long as the item is manufactured in conformance with the details of the approved drawings, specifications, or other data referred to. No modification in the approved design, construction, or materials is to be adopted until the modification has been presented for consideration by the Commandant and confirmation received that the proposed alteration is acceptable.

NOTICE: Where a manufacturer of safety-at-sea equipment is offering for sale to the maritime industry, directly or indirectly, equipment represented to be approved, which fails to conform with either the design details or material specifications, or both, as approved by the Coast Guard, immediate action may be taken to invoke the various penalties and sanctions provided by law including prosecution under 46 U.S.C. 3318, which provides:

"A person that knowingly manufactures, sells, offers for sale, or possesses with intent to sell, any equipment subject to this part *(Part B. of Subtitle II of Title 46 U.S.C.).* and the equipment is so defective as to be insufficient to accomplish the purpose for which it is intended, shall be fined not more than $10,000, imprisoned for not more than 5 years or both."